ZONE	LTR	REVISION DESCRIPTION	DATE	APPROVED
	—	RELEASED FOR PRODUCTION	12/6/83	

4 amp fuse ok — replace w/ 4 amp slo-blo

FI 3A/250v — surge limiting

Snubbing circuit

Kick start latch

Darlington pair

Final wire

drives, est 2.2 2.1A

PRIMARY COMMON

SEC. COM.

NOTE: ALL RESISTORS' VALUES IN OHMS UNLESS OTHERWISE SPECIFIED.

626

RELEASED

DRAFT A.G.	DATE 9-29-83	TITLE	SCHEMATIC – 95W SWITCHING POWER SUPPLY
CHECK E. Mosher	DATE 12-6-83		
DESIGN	DATE		
APPD E. Mosher	DATE 12-6-83		
APPD W. Barnett	DATE 12-6-83		
tandy		DWG NO 8000213	SIZE D
		SCALE NONE	SHEET 1 OF 1